

Interoffice Memo

One Greenwich Plaza, Greenwich, Connecticut 06830

Originating Office: Seattle Cement Plant

Date: June 27, 1980

TO:

Ken Rone

FROM:

Paul Burton

SUBJECT:

Shutdown of Old Part Plant for Insulator Cleaning

and Hot Spot Repairs

On June 26, 1980, the Electrical Department shut down the 2300-volt supply to accomplish much needed preventive maintenance in the high voltage area of the raw mills. Auxiliary power supplies were rented to maintain operation of the slurry tank agitators and furnish lighting where needed. Previous shutdowns were scheduled for March 22nd and April 26th. Due to plant operational priorities, these shutdowns were postponed. Following an infra-scan survey by Westinghouse, hot spots were discovered that placed the abovementioned preventive maintenance in a priority classification.

A thorough cleaning of all insulators and bus bars was accomplished. Potential problems as indicated by the Westinghouse survey were corrected. This includes the high voltage and the D.C. equipment where dust accumulation could cause tracking and possible fault conditions.

PB/me

cc: T. G. Wells

1261029